CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
MISCELLANEOUS GRAY IRON CASTINGS

USING DEPARTMENT: Water Utility **ISSUED:** 05/10/84 **REVIEWED:** 10/01/13 **REVISED:** 10/01/13

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Gray Iron Castings, ASTM A48 Class 30B minimum, for valve boxes and bases, sanitary sewer cleanouts and other municipal construction castings as ordered.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/97	EJ (formerly East Jordan Iron Works) 216 East 6th Street San Angelo, TX 76903	Includes Catalogue No. 1566 frame and cover for Wastewater Cleanout Cover in unpaved areas *(See Standards No. 520S-4 and 520S-4A*) Includes water valve box 33470900 and square lid 33170901 for reclaimed water See note below	W. Flynn
11/08/01	CALCUTTA FOUNDRY, LTD SIGMA CORP. P.O. Box 300 Cream Ridge, NJ 08514	See note below	K. Flowers
01/02/04	PLPL FOUNDRY (INDIA) STAR PIPE PRODUCTS 4018 Westhollow Pkwy. Houston, TX 77082	Water Valve Box base, cover, and paving ring	R. Lamb
10/01/04	VICTORY IRON WORKS, LTD (INDIA) ACCUCAST 415 South 21st Avenue Waco, TX 76706	Water Valve Box base and C-3 and C-7 covers Wastewater Cleanout base	R. Lamb

NOTE:

1. Must be in compliance with above description with City of Austin Standard Details and construction specifications. Machined surfaces shall be true to dimensions shown; no principal dimension shall vary by more than $\frac{1}{8}$" from dimension given on Standard Detail. Rocking or interference in fit between interchanged frame and covers is unacceptable.