



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST**

for

**MISCELLANEOUS GRAY IRON CASTINGS**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 05/10/84    **REVIEWED:** 10/01/15    **REVISED:** 10/01/15

**PREPARED BY:** Bill Flynn, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Gray Iron Castings, ASTM A48 Class 30B minimum, for valve boxes and bases, sanitary sewer cleanouts and other municipal construction castings as ordered.

| <b>LISTING DATE</b> | <b>MANUFACTURER</b>  | <b>PRODUCT IDENTIFICATION/COMMENT</b>  | <b>APPROVAL</b> |
|---------------------|--|--|-----------------|
| 07/01/97            | EJ (formerly East Jordan Iron Works)<br>216 East 6 <sup>th</sup> Street<br>San Angelo, TX 76903    | Includes Catalogue No.1564Z frame (Product No. 00156411) and 1564A cover (Product No. 00156454A01) for Wastewater Cleanout Cover in paved and unpaved areas ( <i>See Standards No. 520S-4 and 520S-4A</i> )<br>Includes water valve box 33470900 and square lid 33170901 for reclaimed water<br>See note below | W. Flynn        |
| 11/08/01            | CALCUTTA FOUNDRY, LTD<br>SIGMA CORP.<br>P.O. Box 300<br>Cream Ridge, NJ 08514                      | See note below   | K. Flowers      |
| 01/02/04            | PLPL FOUNDRY (INDIA)<br>STAR PIPE PRODUCTS<br>4018 Westhollow Pkwy.<br>Houston, TX 77082           | Water Valve Box base, cover, and paving ring   | R. Lamb         |
| 10/01/04            | VICTORY IRON WORKS, LTD (INDIA)<br>ACCUCAST<br>415 South 21 <sup>st</sup> Avenue<br>Waco, TX 76706 | Water Valve Box base and C-3 and C-7 covers<br>Wastewater Cleanout base  | R. Lamb         |

**NOTE:**

1. Must be in compliance with above description with City of Austin Standard Details and construction specifications. Machined surfaces shall be true to dimensions shown; no principal dimension shall vary by more than 1/8" from dimension given on Standard Detail. Rocking or interference in fit between interchanged frame and covers is unacceptable.