



**CITY OF AUSTIN  
QUALIFIED PRODUCTS LIST**  
for

**POLYETHYLENE TUBING FOR RECLAIMED WATER SERVICES**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 01/01/10    **REVIEWED:** 04/01/15    **REVISED:** 04/01/15

**PREPARED BY:** Robert Lamb, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Tubing, polyethylene, meeting ASTM D 2737, CTS-OD ¾" thru 2", made of PE 4710, minimum Pressure Class 250 psi (SDR-9), solid purple wall or purple shell over clear or blue core, with contrasting-color heat-indented printline. Only compression fittings recommended by the manufacturer used with stainless steel insert stiffeners may be used.

<b>LISTING DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>	<b>APPROVAL</b>
01/01/10	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockaway, NJ 07866	EndoPure Purple shell (Pantone 522C) over Clear core with White printline	R. Lamb
04/01/15	SILVER-LINE PLASTICS CORP. 900 Riverside Drive Asheville, NC 28804	Purple shell (Pantone 522C) over Blue core with Black printline	R. Lamb

**NOTE:**

1. Printline shall include all markings required by ASTM D 2737: nominal tubing size, type of PE plastic tubing material, pressure rating for water, ASTM designation D 2737, manufacturer's name or trademark and code, tubing test category. In addition, the printline shall include the date of manufacture that is recognizable as a date, and manufacturer's production code that includes resin source, manufacturing location, and extrusion line.
2. Tracer tape meeting SPL WW-597 to be installed 12 inches above top of tubing.