



**CITY OF AUSTIN
QUALIFIED PRODUCTS LIST**
for
POLYETHYLENE TUBING FOR RECLAIMED WATER SERVICES

USING DEPARTMENT: Water Utility **ISSUED:** 01/01/10 **REVIEWED:** 01/01/10 **REVISED:** 01/01/10

PREPARED BY: Robert Lamb, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Tubing, polyethylene, meeting ASTM D 2737, CTS-OD ¾" thru 2", made of PE 3408, minimum Pressure Class 200 psi (SDR-9), solid purple (Pantone 512) exterior and clear interior, contrasting-color heat-indenting printline. Only compression fittings recommended by the manufacturer used with stainless steel insert stiffeners may be used.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/01/10	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockaway, NJ 07866	EndoPure	R. Lamb

NOTE:

1. Printline shall include all markings required by ASTM D 2737: nominal tubing size, type of PE plastic tubing material, pressure rating for water, ASTM designation D 2737, manufacturer's name or trademark and code, tubing test category. In addition, the printline shall include the date of manufacture that is recognizable as a date, and manufacturer's production code that includes resin source, manufacturing location, and extrusion line.
2. Tracer tape meeting SPL WW-597 to be installed 12 inches above top of tubing.