

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	1	1 1 0 5	15650
SYS	PERMIT NUMBER	SET	YEAR MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I "800"

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE			
	REPORTED	PERMITTED		VALUE	UNITS				
316164024 FEC. COLI DLY AVG	REPORTED		<2	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED		20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED		<2	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED		75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED		0.70	MGD	0	02	CONT	11	CONT
	PERMITTED					02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED		<2.0	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED		5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED		2.99	NTU	0	12/30	12/MONTH	03	GRABPKLOAD
	PERMITTED		3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0018247	NUMBER	0	01		01	
	PERMITTED					01	NA	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		12/11/12	DATE	0	01		01	
	PERMITTED					01	NA	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0	01		01	
	PERMITTED					01	NA	01	NA
	REPORTED								
	PERMITTED								
	REPORTED								
	PERMITTED								

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981. Walnut Creek WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE		
	Mike Welch		1	1	06
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR	MO.	DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1	1	06
AREA CODE	NUMBER	EXECUTIVE OFFICER	YEAR	MO.	DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	1 1 YEAR	0 5 MO.	15651 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE			
	REPORTED	PERMITTED			VALUE	UNITS	TYPE	TYPE
000085342 TRANSFER DAYS MON	REPORTED	PERMITTED	0 01	01	31	DAY	01	
				NA			01	NA
316164024 FEC. COLI DLY AVG	REPORTED	PERMITTED	0 11	2/WEEK	>4	#/100 ML	03	GRABPKLOAD
				2/WEEK	200.000		03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	PERMITTED	0 11	2/WEEK	TNTC	#/100 ML	03	GRABPKLOAD
				2/WEEK	800.000		03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED	0 02	CONT	2.03	MGD	11	CONT
				CONT			11	CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED	0 11	2/WEEK	<2.0	MG/L	03	GRABPKLOAD
				2/WEEK	15.000		03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0 01		WW0011708	NUMBER	01	
				NA			01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0 01		12/05/12	DATE	01	
				NA			01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0 01		B	LETTER	01	
				NA			01	NA
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889. FCOLI: May 5, 2011: > result derived from a single 50 mL dilution that yielded a TNTC result.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE


	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1 1 0 6 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1 1 0 6 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	1 1 0 5 YEAR MO.	15652 EID
------------	--------------------------------	----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	PERMITTED				
500507124 FLOW	REPORTED		0	01		01
DAILY AVG	PERMITTED			01	NA	01 NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED		0	01		01
	PERMITTED			01	NA	01 NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		0	01		01
	PERMITTED			01	NA	01 NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		0	01		01
	PERMITTED			01	NA	01 NA
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 31 days and South Austin Regional WWTP transferred reclaimed water 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 1 0 6 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 1 0 6 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY