

## DMR Copy of Record

### Permit

Permit #: TX0067466

Major:

Permittee: AUSTIN, CITY OF  
 Permittee Address: 625 E 10TH ST STE 800  
 AUSTIN, TX 78701

Facility: THOROUGHbred FARMS WWTP  
 Facility Location: 8250 CITATION AVE,2400F E. FMR 973  
 AUSTIN, TX 787670000

Permitted Feature: 001  
 External Outfall

Discharge: 001-A  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: From 08/01/17 to 08/31/17

DMR Due Date: 09/20/17

Status: NetDMR Validated & Complete

### Considerations for Form Completion

### Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

### No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units		
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	5.8					19 - mg/L	0	19/30 - 19 Per Month	GR - GRAB		
					Permit Req.					>=	2 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB		
					Value NODI																
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	1.3						<	6.2	=	17.3	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	11 DAILY AV					<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly		GR - GRAB		
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.5			=	7.7	12 - SU	0	27/30 - 27 Per Month	GR - GRAB		
					Permit Req.							>=	6 MINIMUM			<=		9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2.1				26 - lb/d		=	9.6	=	16.7	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	11 DAILY AV				26 - lb/d		<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
					Value NODI													
					Sample	=	0.039	=	0.196	03 - MGD							29/30 - 29 Per Month	IN - INSTAN
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD						0	05/WK - Five Per Week	IN - INSTAN
					Value NODI													
					Sample					=	1		=	3.1	19 - mg/L		29/30 - 29 Per Month	GR - GRAB
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

No flow readings were recorded on 8/9/17 or 8/10/17 due to the flow chart being inoperable The 2 hour peak flow of 127 GPM on 8/27/17 exceeded the maximum permitted value of 125 GPM

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: ayman.benyamin@austintexas.gov

Date/Time: 2017-09-17 17:55 (Time Zone: -05:00)

Name: Ayman Benyamin

E-Mail: ayman.benyamin@austintexas.gov