

DMR Copy of Record

Permit

Permit #: TX0067466

Major:

Permittee: AUSTIN, CITY OF
 Permittee Address: 625 E 10TH ST STE 800
 AUSTIN, TX 78701

Facility: THOROUGHbred FARMS WWTP
 Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
 AUSTIN, TX 787670000

Permitted Feature: 001
 External Outfall

Discharge: 001-A
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 07/01/17 to 07/31/17

DMR Due Date: 08/20/17

Status: NetDMR Validated & Complete

Considerations for Form Completion

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	5								19 - mg/L	0	24/30 - 24 Per Month	GR - GRAB	
					Permit Req.	>=	2 MO MIN								19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	0.8			26 - lb/d		=	3.4	=	3.5	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d		<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7					=		=	8.5	12 - SU	0	29/30 - 29 Per Month	GR - GRAB
					Permit Req.	>=	6 MINIMUM					<=	9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.7			26 - lb/d		=	7.1	=	11.6	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d		<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units		
						Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.028	=	0.035	03 - MGD								0	01/01 - Daily	IN - INSTAN	
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD										05/WK - Five Per Week	IN - INSTAN
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1.1			=	3.7	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L			05/WK - Five Per Week	GR - GRAB
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

The BOD sample from 7/21/17 was given a result of Laboratory Error (LE) due to not being set up for analysis. The BOD sample from 7/26/17 was given a result of Laboratory Error (LE) due to the incubation temperature going outside the acceptable range. The sample was carried through the analysis and had an unofficial result of <2.0 mg/L BOD with all associated QC within acceptable ranges.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: ayman.benyamin@austintexas.gov

Name: Ayman Benyamin

E-Mail: ayman.benyamin@austintexas.gov

Date/Time: 2017-08-14 07:48 (Time Zone: -05:00)