

DMR Copy of Record

Permit

Permit #: TX0067466

Major:

Permittee: AUSTIN, CITY OF
 Permittee Address: 625 E 10TH ST STE 800
 AUSTIN, TX 78701

Facility: THOROUGHbred FARMS WWTP
 Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
 AUSTIN, TX 787670000

Permitted Feature: 001
 External Outfall

Discharge: 001-A
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 06/01/17 to 06/30/17

DMR Due Date: 07/20/17

Status: NetDMR Validated & Complete

Considerations for Form Completion

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

| Parameter | | Monitoring Location | Season # | Param. NODI | Quantity or Loading | | | | | Quality or Concentration | | | | | # of Ex. | Frequency of Analysis | Sample Type | | | |
|-----------|-------------------------|---------------------|----------|-------------|---------------------|---------|-------------|---------|-------|--------------------------|---------|-------------|---------|-------------|----------|-----------------------|-------------|--------------------------|----------------------|-----------|
| Code | Name | | | | Qualifier 1 | Value 1 | Qualifier 2 | Value 2 | Units | Qualifier 1 | Value 1 | Qualifier 2 | Value 2 | Qualifier 3 | | | | Value 3 | Units | |
| 00300 | Oxygen, dissolved [DO] | 1 - Effluent Gross | 0 | -- | Sample | | | | | | = | 5.6 | | | | 19 - mg/L | 0 | 20/30 - Twenty Per Month | GR - GRAB | |
| | | | | | Permit Req. | | | | | | >= | 2 MO MIN | | | | | | 19 - mg/L | 01/07 - Weekly | GR - GRAB |
| | | | | | Value NODI | | | | | | | | | | | | | | | |
| 00310 | BOD, 5-day, 20 deg. C | 1 - Effluent Gross | 0 | -- | Sample | < | 0.4 | | | 26 - lb/d | | | < | 2.2 | = | 2.9 | 19 - mg/L | 0 | 01/07 - Weekly | GR - GRAB |
| | | | | | Permit Req. | <= | 11 DAILY AV | | | 26 - lb/d | | | <= | 20 DAILY AV | <= | 65 SINGGRAB | 19 - mg/L | | 01/07 - Weekly | GR - GRAB |
| | | | | | Value NODI | | | | | | | | | | | | | | | |
| X 00400 | pH | 1 - Effluent Gross | 0 | -- | Sample | | | | | | = | 7.3 | | | = | 9.1 | 12 - SU | 1 | 23/30 - 23 Per Month | GR - GRAB |
| | | | | | Permit Req. | | | | | | >= | 6 MINIMUM | | | <= | 9 MAXIMUM | 12 - SU | | 01/30 - Monthly | GR - GRAB |
| | | | | | Value NODI | | | | | | | | | | | | | | | |
| 00530 | Solids, total suspended | 1 - Effluent Gross | 0 | -- | Sample | = | 1.3 | | | 26 - lb/d | | | = | 6.8 | = | 15.4 | 19 - mg/L | 0 | 01/07 - Weekly | GR - GRAB |
| | | | | | Permit Req. | <= | 11 DAILY AV | | | 26 - lb/d | | | <= | 20 DAILY AV | <= | 65 SINGGRAB | 19 - mg/L | | 01/07 - Weekly | GR - GRAB |

| Parameter | | Monitoring Location | Season # | Param. NODI | Quantity or Loading | | | | | Quality or Concentration | | | | | # of Ex. | Frequency of Analysis | Sample Type | |
|-----------|--|---------------------|----------|-------------|---------------------|---------|---------------|---------|------------------|--------------------------|----------|-------------|---------|-------------|-----------|-----------------------|-----------------------|-------------|
| Code | Name | | | | Qualifier 1 | Value 1 | Qualifier 2 | Value 2 | Units | Qualifier 1 | Value 1 | Qualifier 2 | Value 2 | Qualifier 3 | | | | Value 3 |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 50050 | Flow, in conduit or thru treatment plant | 1 - Effluent Gross | 0 | -- | Sample | = | 0.02 | = | 0.032 | 03 - MGD | | | | | | 0 | 01/01 - Daily | IN - INSTAN |
| | | | | | Permit Req. | <= | .065 DAILY AV | | Req Mon DAILY MX | 03 - MGD | | | | | | | 05/WK - Five Per Week | IN - INSTAN |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 50060 | Chlorine, total residual | 1 - Effluent Gross | 0 | -- | Sample | | | | | = | 1.1 | | = | 1.8 | 19 - mg/L | 0 | 01/01 - Daily | GR - GRAB |
| | | | | | Permit Req. | | | | | >= | 1 MO MIN | | <= | 4 MO MAX | 19 - mg/L | | 05/WK - Five Per Week | GR - GRAB |
| | | | | | Value NODI | | | | | | | | | | | | | |

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

| Parameter | | Monitoring Location | Field | Type | Description | Acknowledge |
|-----------|------|---------------------|---|------|--|-------------------------------------|
| Code | Name | | | | | |
| 00400 | pH | 1 - Effluent Gross | Quality or Concentration Sample Value 3 | Soft | The provided sample value is outside the permit limit. (Error Code: 1) | <input checked="" type="checkbox"/> |

Comments

The pH result of 9.1 su from 6/7/17 exceeded the permitted limit of 9.0 su.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: ayman.benyamin@austintexas.gov

Date/Time: 2017-07-07 10:33 (Time Zone: -05:00)

Name: Ayman Benyamin

E-Mail: ayman.benyamin@austintexas.gov