

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 04/01/2024 - 04/30/2024

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.9	Max	9.6	
		Min	9.6	Min	9.6	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	54	Avg	61	Avg	79	
		Max	62	Max	68	Max	88	
		Min	48	Min	58	Min	75	
Total Hardness	mg/L as CaCO3	Avg	99	Avg	109	Avg	112	
		Max	110	Max	117	Max	121	
		Min	92	Min	105	Min	108	
Total Solids	mg/L	Avg	239	Avg	268	Avg	248	
		Max	276	Max	310	Max	278	
		Min	204	Min	230	Min	230	
Total Chloramines	mg/L	Avg	2.75	Avg	2.53	Avg	2.56	
		Max	3.00	Max	2.70	Max	2.75	
		Min	2.50	Min	2.25	Min	2.45	
Total Organic Carbon	mg/L	Avg	2.53	Avg	2.63	Avg	2.71	
		Max	2.76	Max	2.66	Max	2.76	
		Min	2.32	Min	2.51	Min	2.64	
Conductivity	umhos/cm	Avg	404	Avg	421	Avg	447	
		Max	411	Max	428	Max	447	
		Min	396	Min	413	Min	446	
Total Trihalomethanes	ug/L	Avg	47.2	Avg	34.5	Avg	31.0	
		Max	48.7	Max	34.5	Max	31.0	
		Min	45.7	Min	34.5	Min	31.0	
Turbidity	NTU	Avg	.04	Avg	.03	Avg	.04	
		Max	.11	Max	.04	Max	.07	
		Min	.02	Min	.02	Min	.02	