

Drinking Water Quality Report
Date Range: 01-SEP-2018 to 30-SEP-2018

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.7
			MAX	9.8	MAX	9.8	MAX	9.8
			MIN	9.5	MIN	9.5	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	66	AVG	60	AVG	69
			MAX	71	MAX	67	MAX	74
			MIN	58	MIN	50	MIN	64
Total Hardness	MG/L	SM 2340 C	AVG	90	AVG	84	AVG	89
			MAX	95	MAX	93	MAX	93
			MIN	85	MIN	77	MIN	85
Total Solids	MG/L	SM 2540 B	AVG	125	AVG	117	AVG	146
			MAX	138	MAX	128	MAX	162
			MIN	114	MIN	110	MIN	134
Chloramines	MG/L	SM 4500-CL F	AVG	2.85	AVG	2.76	AVG	2.76
			MAX	3.35	MAX	3.00	MAX	2.90
			MIN	2.50	MIN	1.90	MIN	2.60
Sulfate	MG/L	SM 4500-SO4 E	AVG	30.1	AVG	24.3	AVG	35.7
			MAX	30.9	MAX	24.3	MAX	35.7
			MIN	29.3	MIN	24.3	MIN	35.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.62	AVG	2.37	AVG	2.31
			MAX	2.74	MAX	2.49	MAX	2.38
			MIN	2.51	MIN	2.15	MIN	2.24
Conductivity	UMHOS/cm	SM 2510 B	AVG	285	AVG	273	AVG	323
			MAX	286	MAX	273	MAX	323
			MIN	284	MIN	273	MIN	323
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	36.8	AVG	23.5	AVG	29.5
			MAX	45.4	MAX	26.2	MAX	31.9
			MIN	31.0	MIN	21.2	MIN	26.5
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02	AVG	0.04
			MAX	0.08	MAX	0.03	MAX	0.09
			MIN	0.04	MIN	0.02	MIN	0.03