

Drinking Water Quality Report  
Date Range: 01-MAY-2019 to 31-MAY-2019

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.7	MAX	9.7
			MIN	9.5	MIN	9.4	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	63	AVG	57	AVG	61
			MAX	71	MAX	74	MAX	69
			MIN	57	MIN	49	MIN	53
Total Hardness	MG/L	SM 2340 C	AVG	89	AVG	85	AVG	82
			MAX	98	MAX	99	MAX	92
			MIN	85	MIN	78	MIN	76
Total Solids	MG/L	SM 2540 B	AVG	138	AVG	141	AVG	143
			MAX	154	MAX	152	MAX	160
			MIN	104	MIN	118	MIN	118
Chloramines	MG/L	SM 4500-CL F	AVG	2.90	AVG	2.67	AVG	2.66
			MAX	3.00	MAX	2.85	MAX	2.80
			MIN	2.65	MIN	2.20	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	10.1	AVG	35.1	AVG	30.7
			MAX	10.1	MAX	35.1	MAX	30.7
			MIN	10.1	MIN	35.1	MIN	30.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.81	AVG	2.46	AVG	2.61
			MAX	3.02	MAX	2.74	MAX	2.80
			MIN	2.69	MIN	2.33	MIN	2.42
Conductivity	UMHOS/cm	SM 2510 B	AVG	278	AVG	275	AVG	298
			MAX	284	MAX	277	MAX	302
			MIN	272	MIN	273	MIN	293
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	34.6	AVG	31.7	AVG	36.0
			MAX	38.6	MAX	34.6	MAX	40.1
			MIN	30.7	MIN	28.7	MIN	31.8
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02	AVG	0.02
			MAX	0.08	MAX	0.05	MAX	0.06
			MIN	0.03	MIN	0.01	MIN	0.02