

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 11/01/2020 - 11/30/2020

Parameter	Units		Davis WTP		Ullrich WTP		Handcox WTP
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6
		Max	9.8	Max	9.7	Max	9.7
		Min	9.5	Min	9.5	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	65	Avg	63	Avg	70
		Max	67	Max	67	Max	80
		Min	59	Min	61	Min	66
Total Hardness	mg/L as CaCO3	Avg	93	Avg	91	Avg	94
		Max	96	Max	95	Max	102
		Min	88	Min	88	Min	90
Total Chloramines	mg/L	Avg	2.96	Avg	2.90	Avg	2.82
		Max	3.10	Max	3.10	Max	2.95
		Min	2.80	Min	2.75	Min	2.70
Total Organic Carbon	mg/L	Avg	2.50	Avg	2.41	Avg	2.34
		Max	2.58	Max	2.48	Max	2.39
		Min	2.38	Min	2.34	Min	2.28
Total Trihalomethanes	ug/L	Avg	29.7	Avg	31.2	Avg	23.9
		Max	30.5	Max	31.2	Max	23.9
		Min	28.9	Min	31.2	Min	23.9
Turbidity	NTU	Avg	0.07	Avg	0.03	Avg	0.03
		Max	0.08	Max	0.08	Max	0.18
		Min	0.05	Min	0.03	Min	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.