

# City of Austin Water Quality Laboratory

## Drinking Water Quality Report

Samples Collected Between 02/01/2022 - 02/28/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.6	Avg	9.5	Avg	9.6	
		Max	9.7	Max	9.7	Max	9.6	
		Min	9.6	Min	9.2	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	70	Avg	65	Avg	77	
		Max	73	Max	70	Max	82	
		Min	66	Min	60	Min	74	
Total Hardness	mg/L as CaCO3	Avg	107	Avg	102	Avg	101	
		Max	110	Max	104	Max	104	
		Min	100	Min	100	Min	98	
Total Solids	mg/L	Avg	214	Avg	223	Avg	227	
		Max	230	Max	240	Max	240	
		Min	194	Min	188	Min	218	
Total Chloramines	mg/L	Avg	2.83	Avg	2.81	Avg	2.74	
		Max	2.95	Max	2.90	Max	2.90	
		Min	2.70	Min	2.70	Min	2.60	
Total Organic Carbon	mg/L	Avg	2.77	Avg	2.54	Avg	2.56	
		Max	2.89	Max	2.70	Max	2.65	
		Min	2.63	Min	2.46	Min	2.49	
Conductivity	umhos/cm	Avg	341	Avg	336	Avg	360	
		Max	341	Max	336	Max	360	
		Min	340	Min	336	Min	360	
Total Trihalomethanes	ug/L	Avg	19.9	Avg	24.7	Avg	23.8	
		Max	20.1	Max	24.7	Max	23.8	
		Min	19.7	Min	24.7	Min	23.8	
Turbidity	NTU	Avg	.05	Avg	.14	Avg	.04	
		Max	.07	Max	9.00	Max	.05	
		Min	.03	Min	.01	Min	.02	