

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 06/01/2022 - 06/30/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.7	
		Max	9.7	Max	9.9	Max	9.7	
		Min	9.7	Min	9.6	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	62	Avg	60	Avg	68	
		Max	66	Max	64	Max	70	
		Min	58	Min	52	Min	64	
Total Hardness	mg/L as CaCO3	Avg	91	Avg	89	Avg	92	
		Max	95	Max	94	Max	94	
		Min	86	Min	82	Min	89	
Total Solids	mg/L	Avg	217	Avg	229	Avg	217	
		Max	246	Max	236	Max	228	
		Min	202	Min	224	Min	206	
Total Chloramines	mg/L	Avg	2.80	Avg	2.68	Avg	2.73	
		Max	2.95	Max	2.90	Max	2.95	
		Min	2.65	Min	2.50	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.26	Avg	2.07	Avg	2.18	
		Max	2.40	Max	2.16	Max	2.22	
		Min	2.16	Min	2.00	Min	2.12	
Conductivity	umhos/cm	Avg	312	Avg	324	Avg	338	
		Max	312	Max	324	Max	338	
		Min	312	Min	324	Min	338	
Total Trihalomethanes	ug/L	Avg	26.5	Avg	23.7	Avg	30.9	
		Max	29.4	Max	23.7	Max	30.9	
		Min	23.5	Min	23.7	Min	30.9	
Turbidity	NTU	Avg	.05	Avg	.03	Avg	.03	
		Max	.07	Max	.21	Max	.06	
		Min	.04	Min	.01	Min	.02	