

Drinking Water Quality Report  
Date Range: 01-APR-2010 to 30-APR-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.5
			MAX	10.0	MAX	9.6
			MIN	9.2	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	68	AVG	66
			MAX	80	MAX	70
			MIN	64	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	100	AVG	98
			MAX	111	MAX	101
			MIN	94	MIN	94
Total Solids	MG/L	SM 2540 B	AVG	187	AVG	186
			MAX	204	MAX	202
			MIN	172	MIN	176
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.54	AVG	2.46
			MAX	2.68	MAX	2.50
			MIN	1.80	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.7	AVG	37.0
			MAX	42.3	MAX	37.0
			MIN	29.3	MIN	36.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.69	AVG	2.48
			MAX	2.82	MAX	2.58
			MIN	2.55	MIN	2.35
Conductivity	UMHOS/cm	SM 2510 B	AVG	314	AVG	310
			MAX	321	MAX	311
			MIN	307	MIN	308
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	33.7	AVG	31.6
			MAX	37.0	MAX	34.3
			MIN	31.0	MIN	28.7
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03
			MAX	0.13	MAX	0.05
			MIN	0.05	MIN	0.02