

Drinking Water Quality Report  
Date Range: 01-AUG-2010 to 31-AUG-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.9	MAX	10.1
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	61	AVG	63
			MAX	66	MAX	71
			MIN	56	MIN	56
Total Hardness	MG/L	SM 2340 C	AVG	89	AVG	90
			MAX	93	MAX	98
			MIN	84	MIN	84
Total Solids	MG/L	SM 2540 B	AVG	176	AVG	179
			MAX	188	MAX	194
			MIN	162	MIN	162
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.59	AVG	2.50
			MAX	2.70	MAX	2.79
			MIN	2.50	MIN	2.34
Sulfate	MG/L	SM 4500-SO4 E	AVG	30.0	AVG	30.9
			MAX	30.4	MAX	33.9
			MIN	29.4	MIN	27.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.40	AVG	2.35
			MAX	2.52	MAX	2.53
			MIN	2.31	MIN	2.14
Conductivity	UMHOS/cm	SM 2510 B	AVG	290	AVG	290
			MAX	294	MAX	293
			MIN	288	MIN	287
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	34.6	AVG	31.7
			MAX	41.4	MAX	35.9
			MIN	29.0	MIN	27.0
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.03
			MAX	0.08	MAX	0.06
			MIN	0.03	MIN	0.02