

Drinking Water Quality Report  
Date Range: 01-DEC-2010 to 31-DEC-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	10.0	MAX	9.6
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	74	AVG	70
			MAX	76	MAX	75
			MIN	70	MIN	66
Total Hardness	MG/L	SM 2340 C	AVG	101	AVG	97
			MAX	103	MAX	103
			MIN	99	MIN	93
Total Solids	MG/L	SM 2540 B	AVG	175	AVG	168
			MAX	192	MAX	184
			MIN	164	MIN	154
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.54
			MAX	2.85	MAX	2.75
			MIN	2.50	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	25.7	AVG	35.3
			MAX	29.0	MAX	37.8
			MIN	18.2	MIN	32.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.72	AVG	2.54
			MAX	2.81	MAX	2.69
			MIN	2.62	MIN	2.49
Conductivity	UMHOS/cm	SM 2510 B	AVG	299	AVG	296
			MAX	303	MAX	298
			MIN	295	MIN	294
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	32.3	AVG	33.7
			MAX	38.9	MAX	35.8
			MIN	27.0	MIN	31.2
Turbidity	NTU	SM 2130 B	AVG	0.08	AVG	0.05
			MAX	0.11	MAX	0.15
			MIN	0.03	MIN	0.03