

Drinking Water Quality Report  
Date Range: 01-FEB-2010 to 28-FEB-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.4
			MAX	9.8	MAX	9.6
			MIN	9.5	MIN	9.2
Total Alkalinity	MG/L	SM 2320 B	AVG	64	AVG	60
			MAX	74	MAX	66
			MIN	61	MIN	56
Total Hardness	MG/L	SM 2340 C	AVG	115	AVG	111
			MAX	119	MAX	118
			MIN	110	MIN	104
Total Solids	MG/L	SM 2540 B	AVG	218	AVG	209
			MAX	234	MAX	215
			MIN	208	MIN	204
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.61	AVG	2.51
			MAX	2.70	MAX	2.70
			MIN	2.50	MIN	2.35
Sulfate	MG/L	SM 4500-SO4 E	AVG	53.5	AVG	50.1
			MAX	55.0	MAX	52.5
			MIN	51.0	MIN	47.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.66	AVG	2.39
			MAX	2.76	MAX	2.53
			MIN	2.56	MIN	2.21
Conductivity	UMHOS/cm	SM 2510 B	AVG	368	AVG	361
			MAX	370	MAX	361
			MIN	364	MIN	360
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	12.5	AVG	29.5
			MAX	13.6	MAX	33.4
			MIN	11.4	MIN	24.8
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.25	MAX	0.04
			MIN	0.06	MIN	0.01