

Drinking Water Quality Report
Date Range: 01-JUL-2010 to 31-JUL-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.6
			MAX	10.0	MAX	9.7
			MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	62	AVG	60
			MAX	69	MAX	64
			MIN	53	MIN	57
Total Hardness	MG/L	SM 2340 C	AVG	91	AVG	88
			MAX	98	MAX	92
			MIN	84	MIN	85
Total Solids	MG/L	SM 2540 B	AVG	172	AVG	174
			MAX	184	MAX	188
			MIN	164	MIN	162
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.60	AVG	2.49
			MAX	2.75	MAX	2.65
			MIN	2.30	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	32.3	AVG	29.7
			MAX	34.6	MAX	30.6
			MIN	30.2	MIN	28.5
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.38	AVG	2.19
			MAX	2.49	MAX	2.29
			MIN	2.28	MIN	2.13
Conductivity	UMHOS/cm	SM 2510 B	AVG	293	AVG	286
			MAX	295	MAX	292
			MIN	288	MIN	280
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	35.5	AVG	27.8
			MAX	38.1	MAX	28.7
			MIN	34.2	MIN	26.8
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03
			MAX	0.10	MAX	0.05
			MIN	0.03	MIN	0.02