

Drinking Water Quality Report
Date Range: 01-OCT-2010 to 31-OCT-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.6
			MAX	10.0	MAX	9.7
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	58	AVG	61
			MAX	63	MAX	69
			MIN	52	MIN	54
Total Hardness	MG/L	SM 2340 C	AVG	88	AVG	89
			MAX	94	MAX	96
			MIN	85	MIN	84
Total Solids	MG/L	SM 2540 B	AVG	166	AVG	171
			MAX	177	MAX	180
			MIN	154	MIN	166
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.54	AVG	2.41
			MAX	2.70	MAX	2.55
			MIN	2.25	MIN	1.95
Sulfate	MG/L	SM 4500-SO4 E	AVG	31.1	AVG	35.9
			MAX	32.5	MAX	37.4
			MIN	29.5	MIN	34.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.68	AVG	2.73
			MAX	3.07	MAX	3.10
			MIN	2.44	MIN	2.40
Conductivity	UMHOS/cm	SM 2510 B	AVG	279	AVG	282
			MAX	282	MAX	282
			MIN	276	MIN	281
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	41.5	AVG	23.9
			MAX	67.8	MAX	34.3
			MIN	18.7	MIN	16.3
Turbidity	NTU	SM 2130 B	AVG	0.04	AVG	0.05
			MAX	0.13	MAX	0.11
			MIN	0.02	MIN	0.03