

Drinking Water Quality Report
Date Range: 01-APR-2011 to 30-APR-2011

| Parameter ----- | Units ---- | Method Cd ----- | Davis WTP | | Ullrich WTP | |
|-------------------------|---------------|--------------------|-----------|-----------------|-------------|-------------|
| | | | | T2,T2H ----- | | T3 ----- |
| pH | SU | SM 4500-H B | AVG | 9.8 | AVG | 9.6 |
| | | | MAX | 9.8 | MAX | 9.8 |
| | | | MIN | 9.6 | MIN | 9.5 |
| Total Alkalinity | MG/L | SM 2320 B | AVG | 68 | AVG | 67 |
| | | | MAX | 72 | MAX | 74 |
| | | | MIN | 64 | MIN | 61 |
| Total Hardness | MG/L | SM 2340 C | AVG | 95 | AVG | 93 |
| | | | MAX | 100 | MAX | 100 |
| | | | MIN | 91 | MIN | 88 |
| Total Solids | MG/L | SM 2540 B | AVG | 165 | AVG | 159 |
| | | | MAX | 192 | MAX | 186 |
| | | | MIN | 149 | MIN | 144 |
| Total Chlorine Residual | MG/L | SM 4500-CL F | AVG | 2.60 | AVG | 2.51 |
| | | | MAX | 2.75 | MAX | 2.70 |
| | | | MIN | 2.45 | MIN | 2.35 |
| Sulfate | MG/L | SM 4500-SO4 E | AVG | 37.6 | AVG | 37.8 |
| | | | MAX | 39.1 | MAX | 38.6 |
| | | | MIN | 35.9 | MIN | 37.0 |
| Total Organic Carbon | MG/L | SM 5310 C | AVG | 2.37 | AVG | 2.27 |
| | | | MAX | 2.52 | MAX | 2.35 |
| | | | MIN | 2.18 | MIN | 2.21 |
| Conductivity | UMHOS/cm | SM 2510 B | AVG | 287 | AVG | 279 |
| | | | MAX | 288 | MAX | 282 |
| | | | MIN | 286 | MIN | 276 |
| Total Trihalomethanes | UG/L | EPA 524.3 THM | AVG | 36.0 | AVG | 30.5 |
| | | | MAX | 38.7 | MAX | 33.0 |
| | | | MIN | 32.0 | MIN | 28.3 |
| Turbidity | NTU | SM 2130 B | AVG | 0.08 | AVG | 0.03 |
| | | | MAX | 0.12 | MAX | 0.10 |
| | | | MIN | 0.04 | MIN | 0.03 |