

Drinking Water Quality Report
Date Range: 01-MAR-2011 to 31-MAR-2011

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.7
			MAX	9.9	MAX	9.8
			MIN	9.7	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	72	AVG	69
			MAX	77	MAX	74
			MIN	65	MIN	64
Total Hardness	MG/L	SM 2340 C	AVG	99	AVG	96
			MAX	103	MAX	101
			MIN	94	MIN	91
Total Solids	MG/L	SM 2540 B	AVG	177	AVG	179
			MAX	188	MAX	188
			MIN	168	MIN	162
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.60	AVG	2.43
			MAX	2.85	MAX	2.55
			MIN	2.42	MIN	1.98
Sulfate	MG/L	SM 4500-SO4 E	AVG	38.3	AVG	39.4
			MAX	39.2	MAX	40.3
			MIN	37.1	MIN	38.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.67	AVG	2.47
			MAX	2.79	MAX	2.63
			MIN	2.54	MIN	2.30
Conductivity	UMHOS/cm	SM 2510 B	AVG	293	AVG	294
			MAX	302	MAX	294
			MIN	286	MIN	293
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	34.1	AVG	30.6
			MAX	42.5	MAX	32.8
			MIN	29.1	MIN	28.4
Turbidity	NTU	SM 2130 B	AVG	0.09	AVG	0.04
			MAX	0.13	MAX	0.08
			MIN	0.07	MIN	0.03