

Drinking Water Quality Report
Date Range: 01-AUG-2012 to 31-AUG-2012

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3
-----	----	-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	66	AVG	66
			MAX	73	MAX	77
			MIN	60	MIN	57
Total Hardness	MG/L	SM 2340 C	AVG	98	AVG	100
			MAX	106	MAX	110
			MIN	92	MIN	91
Total Solids	MG/L	SM 2540 B	AVG	196	AVG	191
			MAX	215	MAX	209
			MIN	176	MIN	158
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.60	AVG	2.41
			MAX	2.95	MAX	2.55
			MIN	2.35	MIN	2.20
Sulfate	MG/L	SM 4500-SO4 E	AVG	32.3	AVG	34.0
			MAX	32.4	MAX	34.0
			MIN	32.1	MIN	34.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.73	AVG	2.55
			MAX	2.88	MAX	2.83
			MIN	2.55	MIN	2.32
Conductivity	UMHOS/cm	SM 2510 B	AVG	340	AVG	332
			MAX	341	MAX	332
			MIN	338	MIN	332
Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	45.4	AVG	39.0
			MAX	51.6	MAX	48.2
			MIN	40.7	MIN	32.3
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03
			MAX	0.11	MAX	0.08
			MIN	0.04	MIN	0.02