

Drinking Water Quality Report
Date Range: 01-NOV-2013 to 30-NOV-2013

Parameter	Units	Method Cd	Davis WTP		Ullrich WTP	
				T2,T2H		T3
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.5
			MAX	9.7	MAX	9.7
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	49	AVG	46
			MAX	58	MAX	57
			MIN	38	MIN	36
Total Hardness	MG/L	SM 2340 C	AVG	95	AVG	94
			MAX	105	MAX	106
			MIN	79	MIN	80
Total Solids	MG/L	SM 2540 B	AVG	186	AVG	179
			MAX	194	MAX	187
			MIN	176	MIN	168
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.90	AVG	2.70
			MAX	3.18	MAX	2.85
			MIN	2.70	MIN	2.60
Sulfate	MG/L	SM 4500-SO4 E	AVG	38.7	AVG	38.0
			MAX	39	MAX	38.0
			MIN	38.3	MIN	38.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	3.21	AVG	3.04
			MAX	3.66	MAX	3.26
			MIN	2.91	MIN	2.64
Conductivity	UMHOS/cm	SM 2510 B	AVG	276	AVG	267
			MAX	276	MAX	267
			MIN	275	MIN	267
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	49.6	AVG	61.0
			MAX	94.6	MAX	71.2
			MIN	43.6	MIN	48.6
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.05
			MAX	0.12	MAX	0.19
			MIN	0.03	MIN	0.02