

Drinking Water Quality Report  
Date Range: 01-APR-2013 to 30-APR-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.7
			MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	69	AVG	72
			MAX	75	MAX	95
			MIN	63	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	104	AVG	108
			MAX	110	MAX	132
			MIN	99	MIN	98
Total Solids	MG/L	SM 2540 B	AVG	205	AVG	210
			MAX	236	MAX	243
			MIN	184	MIN	181
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.65	AVG	2.47
			MAX	2.80	MAX	2.70
			MIN	2.48	MIN	2.10
Sulfate	MG/L	SM 4500-SO4 E	AVG	43.0	AVG	40.4
			MAX	43.2	MAX	40.4
			MIN	42.8	MIN	40.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.75	AVG	2.77
			MAX	2.87	MAX	2.87
			MIN	2.52	MIN	2.55
Conductivity	UMHOS/cm	SM 2510 B	AVG	346	AVG	358
			MAX	349	MAX	358
			MIN	342	MIN	358
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	41.0	AVG	36.7
			MAX	47.5	MAX	40.1
			MIN	36.5	MIN	34.4
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.04
			MAX	0.10	MAX	0.07
			MIN	0.03	MIN	0.02