

Drinking Water Quality Report  
Date Range: 01-JAN-2014 to 31-JAN-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.6
			MAX	9.7	MAX	9.8
			MIN	9.3	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	66	AVG	61
			MAX	70	MAX	66
			MIN	61	MIN	57
Total Hardness	MG/L	SM 2340 C	AVG	120	AVG	116
			MAX	125	MAX	120
			MIN	116	MIN	112
Total Solids	MG/L	SM 2540 B	AVG	206	AVG	203
			MAX	220	MAX	214
			MIN	187	MIN	198
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.67	AVG	2.62
			MAX	2.90	MAX	2.75
			MIN	2.50	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	53.1	AVG	58.9
			MAX	53.5	MAX	58.9
			MIN	52.6	MIN	58.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.87	AVG	2.64
			MAX	3.04	MAX	2.75
			MIN	2.72	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	400	AVG	386
			MAX	400	MAX	386
			MIN	400	MIN	386
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	29.1	AVG	36.6
			MAX	33.0	MAX	39.0
			MIN	25.3	MIN	34.1
Turbidity	NTU	SM 2130 B	AVG	0.11	AVG	0.05
			MAX	0.14	MAX	0.07
			MIN	0.08	MIN	0.03