

Drinking Water Quality Report
Date Range: 01-JUN-2013 to 30-JUN-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.6	MAX	10.0
			MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	64	AVG	65
			MAX	69	MAX	72
			MIN	57	MIN	59
Total Hardness	MG/L	SM 2340 C	AVG	99	AVG	101
			MAX	104	MAX	107
			MIN	92	MIN	96
Total Solids	MG/L	SM 2540 B	AVG	195	AVG	190
			MAX	240	MAX	199
			MIN	170	MIN	180
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.60	AVG	2.35
			MAX	2.92	MAX	2.50
			MIN	2.35	MIN	2.00
Sulfate	MG/L	SM 4500-SO4 E	AVG	39.3	AVG	37.0
			MAX	42.8	MAX	37.0
			MIN	35.7	MIN	37.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.85	AVG	2.68
			MAX	3.06	MAX	2.78
			MIN	2.52	MIN	2.58
Conductivity	UMHOS/cm	SM 2510 B	AVG	340	AVG	338
			MAX	342	MAX	338
			MIN	337	MIN	338
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	39.4	AVG	39.3
			MAX	44.7	MAX	47.8
			MIN	30.8	MIN	34.0
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.11	MAX	0.06
			MIN	0.03	MIN	0.02