

Drinking Water Quality Report
Date Range: 01-MAR-2013 to 31-MAR-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.9	MAX	9.7
			MIN	9.6	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	74	AVG	78
			MAX	80	MAX	86
			MIN	68	MIN	70
Total Hardness	MG/L	SM 2340 C	AVG	109	AVG	115
			MAX	117	MAX	124
			MIN	102	MIN	107
Total Solids	MG/L	SM 2540 B	AVG	193	AVG	203
			MAX	212	MAX	212
			MIN	182	MIN	198
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.58	AVG	2.56
			MAX	2.70	MAX	2.70
			MIN	2.42	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	45.1	AVG	41.9
			MAX	47.9	MAX	41.9
			MIN	42.2	MIN	41.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.72	AVG	2.82
			MAX	2.92	MAX	3.00
			MIN	2.54	MIN	2.73
Conductivity	UMHOS/cm	SM 2510 B	AVG	369	AVG	376
			MAX	374	MAX	376
			MIN	364	MIN	376
Total Trihalomethanes	UG/L	524.3 THM	AVG	37.3	AVG	34.8
			MAX	38.5	MAX	40.3
			MIN	35.4	MIN	31.3
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.04
			MAX	0.10	MAX	0.06
			MIN	0.03	MIN	0.03