

Drinking Water Quality Report  
Date Range: 01-APR-2014 to 30-APR-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	9.8
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	65	AVG	66
			MAX	70	MAX	72
			MIN	59	MIN	58
Total Hardness	MG/L	SM 2340 C	AVG	104	AVG	106
			MAX	109	MAX	111
			MIN	98	MIN	98
Total Solids	MG/L	SM 2540 B	AVG	178	AVG	195
			MAX	206	MAX	208
			MIN	152	MIN	166
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.62	AVG	2.61
			MAX	2.75	MAX	2.75
			MIN	2.50	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	47.5	AVG	38.3
			MAX	50.6	MAX	38.3
			MIN	43.8	MIN	38.3
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.80	AVG	2.77
			MAX	3.09	MAX	2.86
			MIN	2.59	MIN	2.62
Conductivity	UMHOS/cm	SM 2510 B	AVG	363	AVG	373
			MAX	364	MAX	373
			MIN	362	MIN	373
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	31.4	AVG	48.7
			MAX	38.7	MAX	59.0
			MIN	25.2	MIN	39.4
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03
			MAX	0.11	MAX	0.05
			MIN	0.03	MIN	0.02