

Drinking Water Quality Report  
Date Range: 01-AUG-2014 to 31-AUG-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.7
			MAX	9.7	MAX	9.8
			MIN	9.6	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	55	AVG	60
			MAX	62	MAX	65
			MIN	49	MIN	56
Total Hardness	MG/L	SM 2340 C	AVG	91	AVG	97
			MAX	98	MAX	104
			MIN	85	MIN	92
Total Solids	MG/L	SM 2540 B	AVG	185	AVG	192
			MAX	200	MAX	204
			MIN	174	MIN	185
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.86	AVG	2.69
			MAX	3.15	MAX	2.90
			MIN	2.40	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	37.3	AVG	39.6
			MAX	39.0	MAX	39.6
			MIN	35.5	MIN	39.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.71	AVG	2.60
			MAX	3.19	MAX	2.69
			MIN	2.46	MIN	2.49
Conductivity	UMHOS/cm	SM 2510 B	AVG	337	AVG	346
			MAX	339	MAX	346
			MIN	335	MIN	346
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	47.7	AVG	30.5
			MAX	57.1	MAX	39.7
			MIN	37.7	MIN	21.6
Turbidity	NTU	SM 2130 B	AVG	0.04	AVG	0.04
			MAX	0.14	MAX	0.08
			MIN	0.02	MIN	0.02