

Drinking Water Quality Report
Date Range: 01-DEC-2014 to 31-DEC-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.6
			MAX	9.6	MAX	9.7
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	69	AVG	63
			MAX	78	MAX	67
			MIN	64	MIN	59
Total Hardness	MG/L	SM 2340 C	AVG	108	AVG	105
			MAX	118	MAX	110
			MIN	104	MIN	102
Total Solids	MG/L	SM 2540 B	AVG	188	AVG	187
			MAX	206	MAX	192
			MIN	172	MIN	178
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.86	AVG	2.78
			MAX	3.05	MAX	3.00
			MIN	2.65	MIN	2.55
Sulfate	MG/L	SM 4500-SO4 E	AVG	39.1	AVG	42.6
			MAX	39.3	MAX	42.6
			MIN	38.9	MIN	42.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	3.06	AVG	2.77
			MAX	3.18	MAX	2.90
			MIN	2.94	MIN	2.59
Conductivity	UMHOS/cm	SM 2510 B	AVG	362	AVG	362
			MAX	362	MAX	362
			MIN	362	MIN	362
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	38.2	AVG	40.2
			MAX	39.9	MAX	43.5
			MIN	35.0	MIN	38.6
Turbidity	NTU	SM 2130 B	AVG	0.08	AVG	0.02
			MAX	0.10	MAX	0.05
			MIN	0.04	MIN	0.01