

Drinking Water Quality Report
Date Range: 01-JUN-2014 to 30-JUN-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.7
			MIN	9.5	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	56	AVG	58
			MAX	62	MAX	65
			MIN	49	MIN	52
Total Hardness	MG/L	SM 2340 C	AVG	94	AVG	97
			MAX	99	MAX	102
			MIN	87	MIN	88
Total Solids	MG/L	SM 2540 B	AVG	182	AVG	189
			MAX	195	MAX	198
			MIN	168	MIN	176
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.60	AVG	2.43
			MAX	2.85	MAX	2.60
			MIN	2.35	MIN	2.20
Sulfate	MG/L	SM 4500-SO4 E	AVG	42.1	AVG	42.2
			MAX	44.8	MAX	42.2
			MIN	39.3	MIN	42.2
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.87	AVG	2.72
			MAX	3.07	MAX	2.89
			MIN	2.76	MIN	2.52
Conductivity	UMHOS/cm	SM 2510 B	AVG	341	AVG	344
			MAX	341	MAX	344
			MIN	340	MIN	344
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	45.6	AVG	50.5
			MAX	59.9	MAX	56.4
			MIN	35.8	MIN	48.2
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02
			MAX	0.13	MAX	0.04
			MIN	0.02	MIN	0.01