

Drinking Water Quality Report
Date Range: 01-MAR-2014 to 31-MAR-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.6
			MAX	9.7	MAX	9.7
			MIN	9.3	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	68	AVG	69
			MAX	75	MAX	75
			MIN	62	MIN	63
Total Hardness	MG/L	SM 2340 C	AVG	111	AVG	112
			MAX	117	MAX	121
			MIN	104	MIN	105
Total Solids	MG/L	SM 2540 B	AVG	201	AVG	208
			MAX	226	MAX	231
			MIN	188	MIN	196
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.62
			MAX	2.80	MAX	2.75
			MIN	2.58	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	49.7	AVG	45.5
			MAX	50.8	MAX	45.5
			MIN	48.5	MIN	45.5
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.80	AVG	2.67
			MAX	2.88	MAX	2.87
			MIN	2.75	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	375	AVG	375
			MAX	376	MAX	375
			MIN	373	MIN	375
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	29.3	AVG	36.1
			MAX	33.4	MAX	37.8
			MIN	22.2	MIN	31.9
Turbidity	NTU	SM 2130 B	AVG	0.08	AVG	0.04
			MAX	0.11	MAX	0.07
			MIN	0.05	MIN	0.03