

Drinking Water Quality Report
Date Range: 01-NOV-2014 to 30-NOV-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	65	AVG	64
			MAX	72	MAX	70
			MIN	56	MIN	57
Total Hardness	MG/L	SM 2340 C	AVG	101	AVG	102
			MAX	108	MAX	109
			MIN	92	MIN	93
Total Solids	MG/L	SM 2540 B	AVG	173	AVG	173
			MAX	188	MAX	184
			MIN	143	MIN	152
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.98	AVG	2.90
			MAX	3.15	MAX	3.10
			MIN	2.80	MIN	2.75
Sulfate	MG/L	SM 4500-SO4 E	AVG	34	AVG	35.9
			MAX	34.1	MAX	35.9
			MIN	33.9	MIN	35.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	3.07	AVG	2.92
			MAX	3.16	MAX	3.06
			MIN	2.95	MIN	2.80
Conductivity	UMHOS/cm	SM 2510 B	AVG	343	AVG	345
			MAX	344	MAX	345
			MIN	341	MIN	345
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	42.5	AVG	41.4
			MAX	45.6	MAX	48.0
			MIN	37.1	MIN	37.8
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03
			MAX	0.09	MAX	0.07
			MIN	0.03	MIN	0.02