

Drinking Water Quality Report
Date Range: 01-DEC-2015 to 31-DEC-2015

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.5	AVG	9.5
			MAX	9.9	MAX	9.7	MAX	9.6
			MIN	9.4	MIN	9.2	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	48	AVG	49	AVG	65
			MAX	60	MAX	63	MAX	69
			MIN	44	MIN	43	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	93	AVG	95	AVG	89
			MAX	105	MAX	110	MAX	93
			MIN	88	MIN	89	MIN	85
Total Solids	MG/L	SM 2540 B	AVG	166	AVG	171	AVG	165
			MAX	190	MAX	202	MAX	188
			MIN	120	MIN	146	MIN	119
Chloramines	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.54	AVG	2.64
			MAX	2.95	MAX	2.65	MAX	3.00
			MIN	2.52	MIN	2.35	MIN	1.90
Sulfate	MG/L	SM 4500-SO4 E	AVG	40.0	AVG	53.0	AVG	36.0
			MAX	40.2	MAX	53.0	MAX	35.8
			MIN	40.2	MIN	53.0	MIN	35.8
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.74	AVG	2.57	AVG	2.67
			MAX	2.89	MAX	2.72	MAX	2.77
			MIN	2.53	MIN	2.25	MIN	2.57
Conductivity	UMHOS/cm	SM 2510 B	AVG	304	AVG	304	AVG	317
			MAX	308	MAX	304	MAX	317
			MIN	300	MIN	304	MIN	317
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	52.5	AVG	44.5	AVG	40.5
			MAX	61.1	MAX	45.6	MAX	42.1
			MIN	46.8	MIN	43.0	MIN	38.8
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03	AVG	0.04
			MAX	0.16	MAX	0.08	MAX	0.06
			MIN	0.02	MIN	0.02	MIN	0.03