

Drinking Water Quality Report  
Date Range: 01-FEB-2015 to 28-FEB-2015

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.5
			MAX	9.6	MAX	9.6
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	62	AVG	64
			MAX	67	MAX	70
			MIN	58	MIN	60
Total Hardness	MG/L	SM 2340 C	AVG	113	AVG	114
			MAX	116	MAX	121
			MIN	110	MIN	108
Total Solids	MG/L	SM 2540 B	AVG	191	AVG	191
			MAX	214	MAX	202
			MIN	165	MIN	178
Chloramines	MG/L	SM 4500-CL F	AVG	2.64	AVG	2.55
			MAX	2.85	MAX	2.70
			MIN	2.45	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	48.0	AVG	48.7
			MAX	48.3	MAX	48.7
			MIN	47.6	MIN	48.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.61	AVG	2.46
			MAX	2.68	MAX	2.57
			MIN	2.50	MIN	2.38
Conductivity	UMHOS/cm	SM 2510 B	AVG	381	AVG	373
			MAX	382	MAX	373
			MIN	380	MIN	373
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	30.6	AVG	31.7
			MAX	32.8	MAX	32.6
			MIN	28.3	MIN	30.6
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.02
			MAX	0.08	MAX	0.04
			MIN	0.05	MIN	0.01