

Drinking Water Quality Report
Date Range: 01-JAN-2015 to 31-JAN-2015

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.6
			MAX	9.6	MAX	9.8
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	70	AVG	66
			MAX	77	MAX	73
			MIN	63	MIN	63
Total Hardness	MG/L	SM 2340 C	AVG	114	AVG	112
			MAX	122	MAX	118
			MIN	108	MIN	108
Total Solids	MG/L	SM 2540 B	AVG	201	AVG	193
			MAX	216	MAX	196
			MIN	190	MIN	190
Chloramines	MG/L	SM 4500-CL F	AVG	2.64	AVG	2.61
			MAX	2.75	MAX	2.75
			MIN	2.50	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	41.6	AVG	42.8
			MAX	42.1	MAX	42.8
			MIN	41.1	MIN	42.8
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.89	AVG	2.70
			MAX	3.10	MAX	2.93
			MIN	2.58	MIN	2.43
Conductivity	UMHOS/cm	SM 2510 B	AVG	391	AVG	381
			MAX	392	MAX	381
			MIN	390	MIN	381
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	29.6	AVG	30.7
			MAX	30.9	MAX	31.3
			MIN	28.4	MIN	30.1
Turbidity	NTU	SM 2130 B	AVG	0.08	AVG	0.03
			MAX	0.10	MAX	0.05
			MIN	0.06	MIN	0.02