

Drinking Water Quality Report
Date Range: 01-JUL-2015 to 31-JUL-2015

| Parameter ----- | Units ---- | Method Cd ----- | Davis WTP | | Ullrich WTP | |
|-----------------------|---------------|-----------------------|-----------|-----------------|-------------|-------------|
| | | | | T2,T2H ----- | | T3 ----- |
| pH | SU | SM 4500-H B | AVG | 9.7 | AVG | 9.7 |
| | | | MAX | 9.8 | MAX | 9.9 |
| | | | MIN | 9.5 | MIN | 9.5 |
| Total Alkalinity | MG/L | SM 2320 B | AVG | 42 | AVG | 46 |
| | | | MAX | 45 | MAX | 51 |
| | | | MIN | 38 | MIN | 42 |
| Total Hardness | MG/L | SM 2340 C | AVG | 86 | AVG | 91 |
| | | | MAX | 90 | MAX | 97 |
| | | | MIN | 84 | MIN | 88 |
| Total Solids | MG/L | SM 2540 B | AVG | 158 | AVG | 159 |
| | | | MAX | 198 | MAX | 198 |
| | | | MIN | 132 | MIN | 138 |
| Chloramines | MG/L | SM 4500-CL F | AVG | 2.85 | AVG | 2.73 |
| | | | MAX | 3.05 | MAX | 3.05 |
| | | | MIN | 2.40 | MIN | 2.25 |
| Sulfate | MG/L | SM 4500-SO4 E | AVG | 46.0 | AVG | 44.0 |
| | | | MAX | 46.3 | MAX | 44.4 |
| | | | MIN | 45.6 | MIN | 44.4 |
| Total Organic Carbon | MG/L | SM 5310 C | AVG | 2.52 | AVG | 2.48 |
| | | | MAX | 2.83 | MAX | 2.60 |
| | | | MIN | 2.29 | MIN | 2.33 |
| Conductivity | UMHOS/cm | SM 2510 B | AVG | 311 | AVG | 319 |
| | | | MAX | 312 | MAX | 319 |
| | | | MIN | 310 | MIN | 319 |
| Total Trihalomethanes | UG/L | EPA 524.2 & 524.3 THM | AVG | 65.9 | AVG | 50.5 |
| | | | MAX | 79.8 | MAX | 61.1 |
| | | | MIN | 39.0 | MIN | 32.9 |
| Turbidity | NTU | SM 2130 B | AVG | 0.05 | AVG | 0.02 |
| | | | MAX | 0.09 | MAX | 0.03 |
| | | | MIN | 0.03 | MIN | 0.01 |