

Drinking Water Quality Report
Date Range: 01-JUN-2015 to 30-JUN-2015

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.7
			MAX	9.8	MAX	9.8
			MIN	9.4	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	41	AVG	44
			MAX	44	MAX	49
			MIN	36	MIN	39
Total Hardness	MG/L	SM 2340 C	AVG	89	AVG	92
			MAX	92	MAX	98
			MIN	84	MIN	87
Total Solids	MG/L	SM 2540 B	AVG	156	AVG	163
			MAX	178	MAX	184
			MIN	114	MIN	146
Chloramines	MG/L	SM 4500-CL F	AVG	2.62	AVG	2.49
			MAX	2.95	MAX	2.75
			MIN	2.40	MIN	2.20
Sulfate	MG/L	SM 4500-SO4 E	AVG	43.8	AVG	45.7
			MAX	44.0	MAX	45.7
			MIN	43.5	MIN	45.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.68	AVG	2.51
			MAX	2.88	MAX	2.66
			MIN	2.38	MIN	2.28
Conductivity	UMHOS/cm	SM 2510 B	AVG	317	AVG	321
			MAX	317	MAX	321
			MIN	316	MIN	321
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	70.2	AVG	60.8
			MAX	83.5	MAX	67.2
			MIN	62.5	MIN	55.4
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.02
			MAX	0.10	MAX	0.04
			MIN	0.03	MIN	0.01