

Drinking Water Quality Report
Date Range: 01-NOV-2015 to 30-NOV-2015

Parameter	Units	Method Cd	Davis WTP			Ullrich WTP		WTP 4
				T2,T2H		T3		T4
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	10.1	MAX	9.7
			MIN	9.4	MIN	9.1	MIN	9.2
Total Alkalinity	MG/L	SM 2320 B	AVG	44	AVG	46	AVG	62
			MAX	51	MAX	55	MAX	67
			MIN	35	MIN	41	MIN	58
Total Hardness	MG/L	SM 2340 C	AVG	86	AVG	88	AVG	87
			MAX	94	MAX	101	MAX	91
			MIN	77	MIN	80	MIN	82
Total Solids	MG/L	SM 2540 B	AVG	144	AVG	141	AVG	153
			MAX	178	MAX	177	MAX	168
			MIN	100	MIN	102	MIN	137
Chloramines	MG/L	SM 4500-CL F	AVG	2.88	AVG	2.76	AVG	2.79
			MAX	3.15	MAX	3.00	MAX	3.20
			MIN	2.60	MIN	2.55	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	36.0	AVG	34.0	AVG	33.0
			MAX	36.8	MAX	33.6	MAX	32.5
			MIN	35.3	MIN	33.6	MIN	32.5
Total Organic Carbon	MG/L	SM 5310 C	AVG	3.22	AVG	2.91	AVG	2.71
			MAX	3.40	MAX	3.18	MAX	2.84
			MIN	3.01	MIN	2.59	MIN	2.57
Conductivity	UMHOS/cm	SM 2510 B	AVG	246	AVG	272	AVG	316
			MAX	249	MAX	272	MAX	316
			MIN	243	MIN	272	MIN	316
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	69.2	AVG	63.5	AVG	40.0
			MAX	81.1	MAX	77.9	MAX	41.9
			MIN	56.1	MIN	51.1	MIN	37.2
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03	AVG	0.05
			MAX	0.14	MAX	0.08	MAX	0.13
			MIN	0.05	MIN	0.01	MIN	0.03