

Drinking Water Quality Report  
Date Range: 01-MAR-2017 to 31-MAR-2017

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.5	AVG	9.6
			MAX	9.8	MAX	9.6	MAX	9.6
			MIN	9.4	MIN	9.3	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	57	AVG	60	AVG	65
			MAX	64	MAX	63	MAX	68
			MIN	51	MIN	57	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	84	AVG	87	AVG	86
			MAX	94	MAX	90	MAX	89
			MIN	77	MIN	83	MIN	82
Total Solids	MG/L	SM 2540 B	AVG	136	AVG	133	AVG	149
			MAX	172	MAX	164	MAX	170
			MIN	120	MIN	119	MIN	134
Chloramines	MG/L	SM 4500-CL F	AVG	2.69	AVG	2.59	AVG	2.63
			MAX	3.20	MAX	3.05	MAX	2.85
			MIN	2.45	MIN	2.25	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	20.0	AVG	32.0	AVG	25.0
			MAX	22.0	MAX	32.0	MAX	24.6
			MIN	17.7	MIN	32.0	MIN	24.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.80	AVG	2.79	AVG	2.82
			MAX	2.91	MAX	2.93	MAX	2.90
			MIN	2.64	MIN	2.62	MIN	2.70
Conductivity	UMHOS/cm	SM 2510 B	AVG	287	AVG	288	AVG	307
			MAX	287	MAX	288	MAX	307
			MIN	287	MIN	288	MIN	307
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	33.2	AVG	37.5	AVG	35.0
			MAX	26.4	MAX	44.6	MAX	37.8
			MIN	41.7	MIN	32.5	MIN	32.0
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03	AVG	0.03
			MAX	0.15	MAX	0.08	MAX	0.05
			MIN	0.03	MIN	0.02	MIN	0.02